



No. F6/DFS/MS/School/WZ/2023/898

Dated:- 28/11/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Jhabban Lal D.A.V. Sr. Sec. Public School Located at J-Block, Paschim Vihar, New Delhi-110063, comprised of Basement + Ground + 02 Upper Floors (BL-2) & Ground + 02 Upper Floors (BL-1) owned/occupied by Jhabban Lal D.A.V. Sr. Sec. Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2019/1338 Dated 26.06.2019. The said premise was re-inspected by the officer concerned of this department on 04.11.2023 in the presence of Sh. Gurbachan Singh (Accountant) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 28/11/2023 for a period of **three years**, subject to compliance of the conditions printed below.

Issued on 28/11/2023 at New Delhi by.

(Atul Garg)

Director

Tel. No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Jhabban Lal D.A.V. Sr. Sec. Public School Located at J-Block, Paschim Vihar, New Delhi-110063.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

  
Principal  
J. L. DAV Public School  
J-Block, Paschim Vihar  
New Delhi-110063

  
V. CHAIRMAN  
J. L. DAV Public School  
J-Block, Paschim Vihar  
New Delhi-110063